

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Mar	7.7	28	Y
2-Mar	7.6	30	Y
3-Mar	7.7	30	Y
4-Mar	7.6	30	Y
5-Mar	7.6	30	Y
6-Mar	7.7	32	Y
7-Mar	7.8	32	Y
8-Mar	7.7	32	Y
9-Mar	7.7	32	Y
10-Mar	7.8	32	Y
11-Mar	7.7	34	Y
12-Mar	7.7	34	Y
13-Mar	7.6	34	Y
14-Mar	7.8	34	Y
15-Mar	7.8	34	Y
16-Mar	7.7	34	Y
17-Mar	7.7	32	Y
18-Mar	7.6	34	Y
19-Mar	7.9	38	Y
20-Mar	7.8	32	Y
21-Mar	7.7	32	Y
22-Mar	7.7	32	Y
23-Mar	7.6	30	Y
24-Mar	7.6	32	Y
25-Mar	7.7	32	Y
26-Mar	7.8	32	Y
27-Mar	7.9	32	Y
28-Mar	7.8	34	Y
29-Mar	7.7	32	Y
30-Mar	7.8	32	Y
31-Mar	7.8	36	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Mar-21
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input style="width: 80%;" type="text"/>	
Alk	<input style="width: 80%;" type="text"/>	(alkalinity)
PO4	<input style="width: 80%;" type="text"/>	(Orthophosphate)
Other	<input style="width: 80%;" type="text"/>	(_____)

Print Name: Zac Bertz

Signature: 
Date: 1-Apr-21

Send to DWP within 10 days after end of sampling period.