

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Jun	7.6	30	Y
2-Jun	7.7	32	Y
3-Jun	7.8	32	Y
4-Jun	7.7	30	Y
5-Jun	7.8	32	Y
6-Jun	7.7	32	Y
7-Jun	7.7	32	Y
8-Jun	7.7	30	Y
9-Jun	7.7	30	Y
10-Jun	7.7	32	Y
11-Jun	7.7	32	Y
12-Jun	7.7	30	Y
13-Jun	7.6	30	Y
14-Jun	7.5	32	Y
15-Jun	7.7	30	Y
16-Jun	7.6	30	Y
17-Jun	7.8	32	Y
18-Jun	7.8	30	Y
19-Jun	7.7	30	Y
20-Jun	7.8	32	Y
21-Jun	7.8	30	Y
22-Jun	7.7	30	Y
23-Jun	7.7	30	Y
24-Jun	7.7	30	Y
25-Jun	7.7	30	Y
26-Jun	7.7	28	Y
27-Jun	7.6	28	Y
28-Jun	7.7	28	Y
29-Jun	7.7	28	Y
30-Jun	7.6	28	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Jun-21
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	<input style="width: 80%;" type="text" value="7.5"/>	
Alk	<input style="width: 80%;" type="text" value="30"/>	(alkalinity)
PO4	<input style="width: 80%;" type="text" value=""/>	(Orthophosphate)
Other	<input style="width: 80%;" type="text" value=""/>	(_____)

Print Name: Zac Bertz

Signature: _____

Date: 1-Jul-21

Send to DWP within 10 days after end of sampling period.