



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SD	Y/N
1					
2					
3					
4	7.1				Y
5					
6					
7					
8					
9					
10					
11					
12					
13	7.2				Y
14					
15					
16					
17					
18					
19					
20					
21					
22	7.1				Y
23					
24					
25					
26					
27					
28					
29	7.0				Y
30					
31					

<<Have minimums been met for this day?

County: Lane Agency: LAKE OSWEGO

ENTRY POINT

EP-A

PWS ID 4100421

FERNRIDGE MOBILE ESTATES

Sample period: July 2021
 Month/year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

Print Name: Kelly Thomas

Signature: [Handwritten Signature]

Date Phone#:

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's 0