



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH  | Alk | Phos | SiM | Y/N |
|-----|-----|-----|------|-----|-----|
| 1   |     |     |      |     |     |
| 2   |     |     |      |     |     |
| 3   |     |     |      |     |     |
| 4   |     |     |      |     |     |
| 5   |     |     |      |     |     |
| 6   | 7.1 |     |      |     | X   |
| 7   |     |     |      |     |     |
| 8   |     |     |      |     |     |
| 9   |     |     |      |     |     |
| 10  |     |     |      |     |     |
| 11  |     |     |      |     |     |
| 12  |     |     |      |     |     |
| 13  |     |     |      |     |     |
| 14  |     |     |      |     |     |
| 15  | 7.0 |     |      |     | X   |
| 16  |     |     |      |     |     |
| 17  |     |     |      |     |     |
| 18  |     |     |      |     |     |
| 19  |     |     |      |     |     |
| 20  |     |     |      |     |     |
| 21  |     |     |      |     |     |
| 22  | 7.0 |     |      |     | X   |
| 23  |     |     |      |     |     |
| 24  |     |     |      |     |     |
| 25  |     |     |      |     |     |
| 26  |     |     |      |     |     |
| 27  |     |     |      |     |     |
| 28  | 7.1 |     |      |     | X   |
| 29  |     |     |      |     |     |
| 30  |     |     |      |     |     |
| 31  |     |     |      |     |     |

<<Have minimums been met for this day?

County: Lane    Agency: LANE COUNTY

## ENTRY POINT

EP-A

PWS ID 4100421

**FERNRIDGE MOBILE ESTATES**

Sample period: July 2023  
Month/year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

Print Name: Keller Thomas

Signature: *[Handwritten Signature]*

Date Phone#: 541-684-8237

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0