



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1					
2	7.1				
3					
4					
5	7.0				
6					
7					
8	7.0				
9					
10					
11	7.0				
12					
13					
14	7.1				
15					
16					
17	7.0				
18					
19					
20	7.0				
21					
22					
23	7.0				
24					
25					
26	7.1				
27					
28	7.0				
29					
30	7.1				
31					

<<Have minimums been met for this day?

County: Linn Agency: LAMB COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100421**

**FERNRIDGE MOBILE ESTATES**

Sample period: November 2023  
Month/year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0

Print Name: Kelly Thomas

Signature: *Kelly Thomas*

Date Phone#:

**Send to DWP within 10 days after end of sampling period**

(No = N = Excursion) Total N's