

Day	pH	Alk	Phos	Sill	Y/N
1	7.0				X
2					
3					
4					
5	7.0				X
6					
7					
8					
9					
10	7.1				X
11					
12					
13					
14	7.1				X
15					
16					
17	7.0				X
18					
19					
20					
21	7.1				X
22					
23					
24	7.1				X
25					
26					
27					
28	7.0				X
29					
30					
31					

(No = N = Excursion) Total N's 0

County: LEED Agency: LANE COUNTY

ENTRY POINT
EP-A
PWS ID 4100421
FERNRIDGE MOBILE ESTATES

Sample period: February 2024
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Print Name: Kelly Thomas
Signature: *Kelly Thomas*
Date Phone#: 541-689-8237

Send to DWP within 10 days after end of sampling period