

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3	7.1				N
4					
5					
6					
7					
8	7.1				N
9					
10					
11	7.1				N
12					
13					
14	7.0				N
15					
16					
17					
18	7.1				N
19					
20					
21					
22	7.1				N
23					
24					
25	7.0				N
26					
27	7.0				N
28					
29					
30	7.0				N
31					

<<Have minimums been met for this day?

County: LEWIS Agency: LAWE COUNTY

ENTRY POINT
EP-A

PWS ID 4100421

FERNRIDGE MOBILE ESTATES

Sample period: March 2024
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

Print Name: Kelly Thomas

Signature: *Kelly Thomas*

Date Phone#: 341-689-8

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N