

<<Have minimums been met for this day?

# ENTRY POINT

## EP-A

PWS ID 4100421

FERNRIDGE MOBILE ESTATES

Sample period: October 2024  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

Day	pH	Alk	Phos	Sill	Y/M
1					X
2	7.1				
3					
4					
5					X
6	7.0				
7					
8					
9					X
10	7.1				
11					
12					
13					X
14	7.1				
15					
16					
17					X
18	7.0				
19					
20					
21					X
22	7.1				
23					
24					X
25	7.1				
26					
27					X
28	7.0				
29					
30					
31					

(No = N = Excursion) Total N's 0

Print Name: Kelly Thomas  
Signature: [Handwritten Signature]  
Date: 10/28/24 Phone: 541-689-8237

Send to DWP within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>