



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sulf	YN
1					
2					
3					
4					
5	7.1				X
6					
7					
8					
9					
10					
11					
12	7.1				X
13					
14					
15					
16					
17					
18					
19					
20	7.0				X
21					
22					
23					
24					
25					
26					
27					
28	7.1				X
29					
30					
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4100421

FERNRIDGE MOBILE ESTATES

Sample period: January 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

Print Name: Kelly Thomas

Signature: *Kelly Thomas*

Date: _____ Phone: _____

Send to DWP within 10 days after end of sampling period