



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.10				Y
2	7.62				Y
3	7.39				Y
4	7.26				Y
5	7.21				Y
6	6.47				N
7	7.52				Y
8	7.23				Y
9	6.95				N
10	6.89				N
11	7.15				Y
12	7.15				Y
13	7.32				Y
14	7.50				Y
15	7.47				Y
16	7.31				Y
17	7.24				Y
18	7.31				Y
19	7.49				Y
20	7.72				Y
21	8.09				Y
22	8.60				Y
23	7.73				Y
24	7.27				Y
25	7.39				Y
26	8.60				Y
27	8.10				Y
28	7.90				Y
29	8.0				Y
30	8.74				Y
31	8.81				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: January 2021
Month/Year

Number of excursions* during this month: 3
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.1	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: KONRAD DIMMITT

Signature: [Handwritten Signature]

Date: 2/1/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 3

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>