



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	9.28				Y
2	9.07				Y
3	8.90				Y
4	7.50				Y
5	8.02				Y
6	7.61				Y
7	7.71				Y
8	8.19				Y
9	8.50				Y
10	8.55				Y
11	8.31				Y
12	7.81				Y
13	7.69				Y
14	7.67				Y
15	7.66				Y
16	7.74				Y
17	7.75				Y
18	7.91				Y
19	8.09				Y
20	8.14				Y
21	8.05				Y
22	7.87				Y
23	7.78				Y
24	7.71				Y
25	7.95				Y
26	8.18				Y
27	8.02				Y
28	8.02				Y
29					
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: CITY OF Lafayette

Entry Point: EP-A

Sample Period: FEBRUARY 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.1	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: KEN RAD, DIMITT
 Signature: [Signature]
 Date: 3/1/21

Send to DWP within 10 days after end of sampling period:

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>