



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.76				Y
2	7.80				Y
3	7.86				Y
4	7.89				Y
5	8.84				Y
6	8.10				Y
7	8.30				Y
8	8.59				Y
9	8.69				Y
10	8.66				Y
11	8.59				Y
12	8.58				Y
13	8.60				Y
14	8.58				Y
15	8.68				Y
16	8.58				Y
17	8.74				Y
18	8.64				Y
19	8.32				Y
20	8.64				Y
21	7.65				Y
22	7.41				Y
23	7.63				Y
24	8.46				Y
25	8.44				Y
26	7.75				Y
27	7.99				Y
28	8.53				Y
29	8.13				Y
30	8.45				Y
31	8.44				Y

ENTRY POINT

<<Have minimums been met for this day? PWS ID: 41 00452

System Name: CITY of Lafayette

Entry Point: EP-A

Sample Period: March 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.1	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

RECEIVED
 APR 02 2021
 Data Mgmt & Compliance
 Drinking Water Program

Print Name: KONRAD DIMMETT

Signature: *Konrad Dimmett*

Date: 4/2/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>