



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.51				Y
2	8.33				Y
3	8.10				Y
4	8.0				Y
5	7.94				Y
6	7.97				Y
7	8.00				Y
8	7.91				Y
9	7.90				Y
10	7.75				Y
11	7.81				Y
12	7.80				Y
13	7.72				Y
14	7.87				Y
15	7.64				Y
16	7.63				Y
17	7.47				Y
18	7.63				Y
19	7.27				Y
20	7.47				Y
21	7.54				Y
22	7.58				Y
23	7.87				Y
24	8.00				Y
25	7.90				Y
26	8.33				Y
27	8.26				Y
28	8.20				Y
29	8.06				Y
30	7.99				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: CITY of Lufayette

Entry Point: EP-A

Sample Period: April 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: KARAD DIMMITT

Signature: [Signature]

Date: 5/3/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>