



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.95				Y
2	7.93				Y
3	7.82				Y
4	7.71				Y
5	7.58				Y
6	7.55				Y
7	7.48				Y
8	7.63				Y
9	8.07				Y
10	8.14				Y
11	8.33				Y
12	7.64				Y
13	7.67				Y
14	8.54				Y
15	8.67				Y
16	8.17				Y
17	8.95				Y
18	7.82				Y
19	7.75				Y
20	7.73				Y
21	7.88				Y
22	8.30				Y
23	8.23				Y
24	8.25				Y
25	8.05				Y
26	7.90				Y
27	7.92				Y
28	7.90				Y
29	8.00				Y
30	8.00				Y
31	8.20				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: May 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: KONRAD D. SMITH

Signature: Konrad D. Smith

Date: 6/2/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>