



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.18				Y
2	8.33				Y
3	8.20				Y
4	8.19				Y
5	8.02				Y
6	7.93				Y
7	7.97				Y
8	7.86				Y
9	8.01				Y
10	8.06				Y
11	7.68				Y
12	8.01				Y
13	8.48				Y
14	8.37				Y
15	8.55				Y
16	8.36				Y
17	8.06				Y
18	7.92				Y
19	8.31				Y
20	8.37				Y
21	8.00				Y
22	8.39				Y
23	7.73				Y
24	7.60				Y
25	7.40				Y
26	7.82				Y
27	7.90				Y
28	7.80				Y
29	8.10				Y
30	8.26				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: June 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Larry Robinson

Signature: [Signature]

Date: 07/02/2021

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>