



Oregon Health Authority

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.07				Y
2	8.00				Y
3	7.90				Y
4	8.26				Y
5	8.03				Y
6	8.07				Y
7	8.03				Y
8	7.88				Y
9	7.65				Y
10	7.89				Y
11	7.80				Y
12	8.05				Y
13	8.04				Y
14	8.01				Y
15	7.88				Y
16	8.06				Y
17	8.04				Y
18	8.16				Y
19	7.77				Y
20	7.44				Y
21	7.59				Y
22	7.56				Y
23	7.41				Y
24	7.59				Y
25	7.57				Y
26	7.95				Y
27	7.87				Y
28	7.92				Y
29	7.92				Y
30	8.18				Y
31	8.20				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 44 **00452**

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: July 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg Robinson

Signature: [Signature]

Date: 08/02/2021

Send to DWP within 10 days after end of sampling period:

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>