



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.48				Y
2	7.80				Y
3	7.70				Y
4	7.77				Y
5	7.59				Y
6	7.56				Y
7	8.05				Y
8	8.13				Y
9	7.91				Y
10	7.90				Y
11	8.29				Y
12	8.47				Y
13	8.66				Y
14	8.61				Y
15	8.40				Y
16	7.53				Y
17	7.60				Y
18	7.21				X
19	7.20				X
20	7.25				X
21	7.26				Y
22	7.56				Y
23	8.00				Y
24	8.20				Y
25	8.33				Y
26	8.21				Y
27	8.58				Y
28	8.56				Y
29	7.62				Y
30	7.32				Y
31	7.24				Y

(No = N = Excursion) Total N's:

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Oct. 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.1"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Greg Robinson

Signature: *Greg Robinson*

Date: 11/01/2021

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>