



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.7				Y
3	7.9				Y
4	7.5				Y
5	7.2				Y
6	7.2				Y
7	7.7				Y
8	7.9				Y
9	7.9				Y
10	8.0				Y
11	9.7				Y
12	9.8				Y
13	9.6				Y
14	9.2				Y
15	8.8				Y
16	7.6				Y
17	7.6				Y
18	7.4				Y
19	7.6				Y
20	7.3				Y
21	7.5				Y
22	7.3				Y
23	7.4				Y
24	7.8				Y
25	7.5				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3				Y
31	7.3				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Dec. 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg Robinson

Signature: [Signature]

Date: 1/3/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>