



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.7				Y
3	7.8				Y
4	7.4				Y
5	7.3				Y
6	7.5				Y
7	7.5				Y
8	7.5				Y
9	7.0				N
10	7.3				Y
11	7.4				Y
12	7.2				Y
13	7.4				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.3				Y
20	7.9				Y
21	7.9				Y
22	8.3				Y
23	7.8				Y
24	7.8				Y
25	7.5				Y
26	8.0				Y
27	8.0				Y
28	7.5				Y
29	7.9				Y
30	7.9				Y
31	8.0				Y

(No = N = Excursion) Total N's 1

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Jan. 2022  
Month/Year

Number of excursions\* during this month: 1  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.1

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Greg Robinson

Signature: [Signature]

Date: 02/01/2022

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>