



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	8.5				Y
3	7.5				Y
4	8.0				Y
5	8.5				Y
6	8.0				Y
7	8.0				Y
8	7.9				Y
9	8.5				Y
10	8.5				Y
11	8.5				Y
12	7.8				Y
13	7.7				Y
14	7.6				Y
15	7.3				Y
16	7.5				Y
17	7.4				Y
18	7.6				Y
19	7.7				Y
20	7.8				Y
21	7.8				Y
22	7.9				X
23	8.0				Y
24	8.3				Y
25	8.4				X
26	8.5				X
27	8.3				Y
28	8.0				X
29	X				X
30	X				X
31	X				X

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Feb. 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

-For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Cory D. Robinson

Signature: [Signature]

Date: 3/3/22

Send to DWP within 10 days after end of sampling period:

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>