



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.3				Y
3	7.2				Y
4	7.3				Y
5	7.2				Y
6	7.2				Y
7	7.6				Y
8	8.1				Y
9	8.2				Y
10	8.3				Y
11	8.4				Y
12	8.4				Y
13	8.4				Y
14	8.3				Y
15	8.2				Y
16	8.1				Y
17	8.0				Y
18	8.0				Y
19	7.9				Y
20	8.0				Y
21	8.1				Y
22	8.2				Y
23	8.1				Y
24	7.9				Y
25	7.8				Y
26	7.8				Y
27	7.7				Y
28	7.8				Y
29	7.9				Y
30	7.9				Y
31	7.5				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: March 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Cory D. Robinson

Signature: [Signature]

Date: 04/04/2022

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>