

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	7.7				Y
5	7.7				Y
6	7.3				Y
7	7.7				Y
8	7.9				Y
9	7.8				Y
10	7.7				Y
11	7.8				Y
12	7.8				Y
13	7.8				Y
14	7.8				Y
15	7.8				Y
16	7.9				Y
17	7.9				Y
18	7.9				Y
19	7.8				Y
20	7.8				Y
21	7.4				X
22	7.6				Y
23	7.8				Y
24	8.4				Y
25	8.5				Y
26	8.1				Y
27	8.3				Y
28	8.3				Y
29	8.2				Y
30	8.0				Y
31	X				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: June - 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2 !

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg D. Robinson

Signature: *Greg D. Robinson*

Date: 07/01/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0