

Day	pH	Alk	Phos	Other	Y/N
1	7.63				Y
2	7.63				Y
3	8.01				Y
4	7.84				Y
5	7.55				Y
6	7.61				Y
7	8.24				Y
8	8.20				Y
9	8.31				Y
10	7.66				Y
11	7.73				Y
12	8.04				Y
13	7.94				Y
14	8.05				Y
15	7.90				Y
16	7.92				Y
17	7.68				Y
18	7.79				Y
19	7.61				Y
20	7.59				Y
21	7.34				Y
22	7.60				Y
23	7.74				Y
24	7.50				Y
25	7.50				Y
26	7.70				Y
27	7.81				Y
28	8.34				Y
29	7.92				Y
30	7.71				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Sept. 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 09/30/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's