

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.65				Y
2	7.83				Y
3	8.40				Y
4	7.68				Y
5	7.65				Y
6	7.45				Y
7	7.70				Y
8	7.85				Y
9	7.80				Y
10	8.02				Y
11	8.11				Y
12	8.01				Y
13	7.91				Y
14	7.88				Y
15	7.68				Y
16	8.07				Y
17	8.26				Y
18	7.78				Y
19	7.66				Y
20	7.70				Y
21	7.76				Y
22	7.81				Y
23	7.93				Y
24	7.77				Y
25	8.10				Y
26	7.98				Y
27	8.20				Y
28	8.20				Y
29	7.50				Y
30	7.40				Y
31	7.50				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Oct. 2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk _____ (Alkalinity)
 PO4 _____ (Orthophosphate)
 Other _____

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 11/4/22

Send to DWP within 10 days after end of sampling period