



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.61				Y
2	7.43				Y
3	7.73				Y
4	7.51				Y
5	7.42				Y
6	9.62				Y
7	9.68				Y
8	9.50				Y
9	9.22				Y
10	9.06				Y
11	9.28				Y
12	7.72				Y
13	7.63				Y
14	7.65				Y
15	7.52				Y
16	7.72				Y
17	7.57				Y
18	7.30				Y
19	8.15				Y
20	8.59				Y
21	9.90				Y
22	9.85				Y
23	8.43				Y
24	7.93				Y
25	8.47				Y
26	8.41				Y
27	7.74				Y
28	8.20				Y
29	7.87				Y
30	8.48				Y
31	8.16				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Jan. 2023
Month/Year Jan.

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 02-02-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0