

Day	pH	Alk	Phos	Other	Y/N
1	8.30				Y
2	7.90				Y
3	8.09				Y
4	8.24				Y
5	7.82				Y
6	7.76				Y
7	8.22				Y
8	7.36				Y
9	7.42				Y
10	7.88				Y
11	8.04				Y
12	7.68				Y
13	8.00				Y
14	7.28				Y
15	7.21				Y
16	7.38				Y
17	7.50				Y
18	7.61				Y
19	7.65				Y
20	8.07				Y
21	7.49				Y
22	8.10				Y
23	7.94				Y
24	8.13				Y
25	7.41				Y
26	7.98				Y
27	7.71				Y
28	7.16				Y
29	7.14				Y
30	8.87				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: April 2023
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 5/3/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's