

Day	pH	Alk	Phos	Other	Y/N
1	7.82				Y
2	7.73				Y
3	7.61				Y
4	9.32				Y
5	8.90				Y
6	8.70				Y
7	7.50				Y
8	8.20				Y
9	8.32				Y
10	8.32				Y
11	8.10				Y
12	8.00				Y
13	8.00				Y
14	8.00				Y
15	8.10				Y
16	8.00				Y
17	7.60				Y
18	7.80				Y
19	7.90				Y
20	8.10				Y
21	7.10				Y
22	8.90				Y
23	7.90				Y
24	8.00				Y
25	7.70				Y
26	7.70				Y
27	7.80				Y
28	7.90				Y
29	7.50				Y
30	7.80				Y
31	8.20				Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: May 2023
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 5 months is a violation. Entry Point and Distribution excursions are cumulative.)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg Robinson

Signature: [Signature]

Date: 06/07/2023

Send to DWP within 10 days after end of sampling period