

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	7.9				Y
3	7.9				Y
4	8.0				Y
5	8.4				Y
6	8.4				Y
7	7.8				Y
8	7.9				Y
9	8.0				Y
10	7.8				Y
11	7.7				Y
12	7.8				Y
13	7.8				Y
14	7.7				Y
15	7.8				Y
16	7.8				Y
17	7.8				Y
18	7.8				Y
19	7.8				Y
20	7.9				Y
21	7.9				Y
22	7.9				Y
23	7.9				Y
24	7.9				Y
25	7.9				Y
26	7.9				Y
27	7.9				Y
28	8.0				Y
29	7.9				Y
30	8.0				Y
31	8.0				Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: July 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH    
Alk  (Alkalinity)  
PO4  (Orthophosphate)  
Other

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 08/01/2023

Send to DWP within 10 days after end of sampling period