

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.03				X
2	8.01				Y
3	8.03				Y
4	8.05				Y
5	8.01				Y
6	8.01				Y
7	8.04				Y
8	8.04				Y
9	8.06				X
10	8.07				Y
11	8.05				Y
12	8.01				X
13	8.05				X
14	8.14				Y
15	8.14				Y
16	8.13				Y
17	8.18				Y
18	8.14				Y
19	8.13				Y
20	8.07				Y
21	8.07				Y
22	8.03				Y
23	8.02				Y
24	8.06				X
25	8.03				Y
26	8.04				Y
27	8.12				Y
28	8.21				Y
29	8.23				X
30	7.68				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Sept. 2023  
Month/Year

Number of excursions\* during this month: 2  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 10/06/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's