

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.76				Y
2	7.85				Y
3	7.83				Y
4	7.88				Y
5	7.93				Y
6	7.94				Y
7	7.79				Y
8	7.74				Y
9	7.86				Y
10	7.94				Y
11	7.97				Y
12	7.84				Y
13	7.77				Y
14	7.74				Y
15	7.76				Y
16	7.88				Y
17	8.05				Y
18	8.12				Y
19	8.16				Y
20	8.15				Y
21	8.00				Y
22	7.80				Y
23	7.66				Y
24	7.59				Y
25	7.62				Y
26	7.68				Y
27	7.68				Y
28	7.68				Y
29	7.74				Y
30	7.86				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Nov. 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 11/06/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0