

Day	pH	Alk	Phos	Other	Y/N
1	7.78				Y
2	7.72				Y
3	7.71				Y
4	7.69				Y
5	7.74				Y
6	7.77				Y
7	7.69				Y
8	7.56				Y
9	7.54				Y
10	7.59				Y
11	7.65				Y
12	7.61				Y
13	7.59				Y
14	7.62				Y
15	7.66				Y
16	7.67				Y
17	7.70				Y
18	7.71				Y
19	7.69				Y
20	7.70				Y
21	7.71				Y
22	7.72				Y
23	7.74				Y
24	7.78				Y
25	7.79				Y
26	7.78				Y
27	7.73				Y
28	7.75				Y
29	7.71				Y
30	7.67				Y
31	7.71				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: Dec. 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Greg A. Robinson

Signature: [Signature]

Date: 01-02-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's