



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.63				Y
2	7.64				Y
3	7.60				Y
4	7.55				Y
5	7.50				Y
6	7.52				Y
7	7.53				Y
8	7.49				Y
9	7.50				Y
10	7.51				Y
11	7.59				Y
12	7.55				Y
13	7.57				Y
14	7.53				Y
15	7.55				Y
16	7.56				Y
17	7.62				Y
18	7.65				Y
19	7.66				Y
20	7.68				Y
21	7.66				Y
22	7.61				Y
23	7.56				Y
24	7.54				Y
25	7.53				Y
26	7.54				X
27	7.57				Y
28	7.60				Y
29	7.59				Y
30	7.60				Y
31	7.59				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: March 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg D. Robinson

Signature: *Greg D. Robinson*

Date: 04/02/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0