

Day	pH	Alk	Phos	Other	Y/N
1	7.61				Y
2	7.59				Y
3	7.60				Y
4	7.64				Y
5	7.65				Y
6	7.64				Y
7	7.67				Y
8	7.69				Y
9	7.66				Y
10	7.66				Y
11	7.68				Y
12	7.69				Y
13	7.69				Y
14	7.70				Y
15	7.73				Y
16	7.73				Y
17	7.73				Y
18	7.73				Y
19	7.74				Y
20	7.72				Y
21	7.75				Y
22	7.75				Y
23	7.75				Y
24	7.76				Y
25	7.75				Y
26	7.75				Y
27	7.75				Y
28	7.74				Y
29	7.74				Y
30	7.74				Y
31	N/A				N/A

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: April - 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg D. Robinson

Signature:

Date: 05/07/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0