

Day	pH	Alk	Phos	Other	Y/N
1	7.83				Y
2	7.84				Y
3	7.86				Y
4	7.88				Y
5	7.89				Y
6	7.87				Y
7	7.88				Y
8	7.86				Y
9	7.86				Y
10	7.86				Y
11	7.88				Y
12	7.89				Y
13	7.90				Y
14	7.90				Y
15	7.92				Y
16	7.93				Y
17	7.92				Y
18	7.91				Y
19	7.89				Y
20	7.92				Y
21	7.96				Y
22	7.95				Y
23	8.02				Y
24	8.00				Y
25	7.90				Y
26	7.88				Y
27	7.72				Y
28	7.69				Y
29	7.72				Y
30	7.74				Y
31	N/A				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: EP-A

Sample Period: June 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg D. Robinson

Signature:

Date: 07/02/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0