

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.77				y
2	7.79				y
3	7.80				y
4	7.81				x
5	7.84				y
6	7.84				y
7	7.88				y
8	7.90				y
9	7.92				y
10	7.94				y
11	7.95				y
12	7.97				y
13	7.96				y
14	7.97				y
15	7.99				y
16	8.00				y
17	8.00				y
18	7.93				y
19	7.87				y
20	7.87				y
21	7.87				x
22	7.88				y
23	7.89				x
24	7.90				x
25	7.93				y
26	7.93				x
27	7.94				y
28	7.94				y
29	7.97				y
30	7.95				y
31	7.95				y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: A

Sample Period: July 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 08-01-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's