



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.93				y
2	7.91				y
3	7.92				y
4	7.92				y
5	7.25				y
6	7.37				y
7	7.24				y
8	8.79				y
9	9.30				y
10	9.30				y
11	8.70				y
12	8.11				y
13	7.70				y
14	7.46				y
15	7.43				y
16	7.55				y
17	7.85				y
18	8.50				y
19	9.13				y
20	8.92				y
21	9.03				y
22	9.30				y
23	7.40				y
24	7.50				y
25	7.60				y
26	7.60				y
27	7.80				y
28	9.30				y
29	8.40				y
30	8.00				y
31	X				/

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: - A

Sample Period: Nov. 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Greg S. Robinson

Signature: [Signature]

Date: 12-03-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0