

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.57				y
2	7.70				y
3	7.60				y
4	7.59				y
5	7.46				y
6	7.53				y
7	7.51				y
8	7.50				y
9	7.60				y
10	7.67				y
11	7.67				y
12	7.65				y
13	7.64				y
14	7.73				y
15	7.69				y
16	7.64				y
17	7.67				y
18	7.65				y
19	7.71				y
20	7.72				y
21	7.61				y
22	7.67				y
23	7.75				y
24	7.84				y
25	8.13				y
26	8.13				y
27	7.86				y
28	7.70				x
29	7.72				y
30	7.78				y
31	7.80				y

(No = N = Excursion) Total N's: 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: A

Sample Period: Jan. 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 02/04/2025

Send to DWP within 10 days after end of
sampling period