

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.76				Y
2	7.73				Y
3	7.81				Y
4	7.89				Y
5	8.04				Y
6	7.95				Y
7	7.83				Y
8	7.77				Y
9	7.74				Y
10	7.64				Y
11	7.67				Y
12	7.68				Y
13	7.75				Y
14	7.73				Y
15	7.73				Y
16	7.71				Y
17	7.68				Y
18	7.64				Y
19	7.63				Y
20	7.66				Y
21	7.65				Y
22	7.59				Y
23	7.63				Y
24	7.51				Y
25	7.45				Y
26	7.63				Y
27	7.40				Y
28	7.43				Y
29					
30					
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: A

Sample Period: Feb. 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg S. Robinson

Signature: [Signature]

Date: 03-03-2025

Send to DWP within 10 days after end of sampling period