

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.59				X
2	7.56				Y
3	7.61				Y
4	7.54				Y
5	7.79				Y
6	7.89				Y
7	8.24				Y
8	7.76				X
9	7.71				Y
10	7.68				Y
11	7.71				X
12	7.76				Y
13	7.83				Y
14	7.74				Y
15	7.77				Y
16	7.74				Y
17	7.75				Y
18	7.75				Y
19	7.71				Y
20	7.75				Y
21	7.76				Y
22	7.82				Y
23	7.77				Y
24	7.76				Y
25	7.79				Y
26	7.79				Y
27	7.83				Y
28	7.83				Y
29	7.77				Y
30	7.82				Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: A

Sample Period: April 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Greg D. Robinson

Signature: [Signature]

Date: 05-01-2025

Send to DWP within 10 days after end of
sampling period