

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.75				Y
2	7.81				Y
3	7.82				Y
4	7.80				Y
5	7.78				Y
6	7.80				Y
7	7.83				Y
8	7.89				Y
9	7.90				Y
10	7.91				Y
11	7.90				Y
12	7.85				Y
13	7.87				Y
14	7.86				Y
15	7.24				Y
16	7.67				Y
17	7.68				Y
18	7.68				Y
19	7.61				Y
20	7.66				Y
21	7.68				Y
22	7.75				Y
23	7.76				Y
24	7.74				Y
25	7.74				Y
26	7.75				Y
27	7.74				Y
28	7.86				Y
29	7.96				Y
30	7.99				Y
31	7.91				Y

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: A

Sample Period: 05/2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH ☒
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Greg S. Robinson

Signature: [Signature]

Date: 06-03-2025

Send to DWP within 10 days after end of
sampling period