

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.91				Y
2	7.85				Y
3	7.84	100			Y
4	7.82				Y
5	7.78				Y
6	7.75				Y
7	7.98				Y
8	7.99				Y
9	7.97				Y
10	7.96				Y
11	7.85				Y
12	7.81				Y
13	7.76				Y
14	7.74				Y
15	7.85				Y
16	7.88				Y
17	7.88				Y
18	7.91				Y
19	7.93				Y
20	7.83				Y
21	7.86				Y
22	7.78				Y
23	7.80				Y
24	7.77				Y
25	7.79				Y
26	7.82				Y
27	7.83				Y
28	7.87				Y
29	7.83				Y
30	7.82				Y
31	N/A				

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: A

Sample Period: 06/2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other

Print Name: Greg S. Robinson

Signature: [Signature]

Date: 07/01/2025

Send to DWP within 10 days after end of sampling period