

Day	pH	Alk	Phos	Other	Y/N
1	7.70				Y
2	7.72				Y
3	7.71				Y
4	7.70				Y
5	7.53				Y
6	7.50				Y
7	7.54				Y
8	7.55				Y
9	7.54				Y
10	7.53				Y
11	7.53				Y
12	7.59				Y
13	7.57				Y
14	7.64				Y
15	7.60				Y
16	7.64				Y
17	7.64				Y
18	7.62				Y
19	7.64				Y
20	7.67				Y
21	7.63				Y
22	7.64				Y
23	7.63				Y
24	7.63				Y
25	7.65				Y
26	7.64				Y
27	7.66				Y
28	7.68				Y
29	7.65				Y
30	7.68				Y
31	7.66				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: A

Sample Period: Aug. 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____

Print Name: Greg Robinson

Signature: [Signature]

Date: 9/8/2025

Send to DWP within 10 days after end of sampling period