

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.86				y
2	7.85				y
3	7.87				y
4	7.87				y
5	7.85				y
6	7.83				y
7	7.79				y
8	7.77				y
9	7.75				y
10	7.72				y
11	7.74				y
12	7.68				y
13	7.70				y
14	7.67				y
15	7.51				y
16	7.46				y
17	7.47				y
18	7.48				y
19	7.47				y
20	7.46				y
21	7.52				y
22	7.60				y
23	7.46				y
24	7.51				y
25	7.51				y
26	7.50				y
27	7.51				y
28	7.53				y
29	7.49				y
30	7.58				y
31					

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: A

Sample Period: Nov. 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH ☐
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Greg Robinson

Signature: [Signature]

Date: 12-01-2025

Send to DWP within 10 days after end of
sampling period