

Day	pH	Alk	Phos	Other	Y/N
1	7.55				y
2	7.55				y
3	7.56				y
4	7.61				y
5	7.59				y
6	7.56				y
7	7.57				y
8	7.55				y
9	7.53				y
10	7.64				y
11	7.59				y
12	7.53				y
13	7.53				y
14	7.54				y
15	7.52				y
16	7.54				y
17	7.50				y
18	7.46				y
19	7.43				y
20	7.55				y
21	7.53				y
22	7.64				y
23	7.52				y
24	7.61				y
25	7.68				y
26	7.73				y
27	7.74				y
28	7.70				y
29	7.67				y
30	7.72				y
31	7.76				y

(No = N = Excursion) Total N's

0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00452

System Name: City of Lafayette

Entry Point: A

Sample Period: Dec. 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2



Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg Robinson

Signature: [Signature]

Date: 01-05-2026

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>