

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.63				Y
2	7.57				Y
3	7.51				Y
4	7.50				Y
5	7.51				Y
6	7.60				Y
7	7.59				Y
8	7.57				Y
9	7.60				Y
10	7.58				Y
11	7.53				Y
12	7.54				Y
13	7.54				Y
14	7.55				Y
15	7.52				Y
16	7.59				Y
17	7.61				Y
18	7.61				Y
19	7.61				Y
20	7.60				Y
21	7.57				Y
22	7.60				Y
23	7.57				Y
24	7.66				Y
25	7.68				Y
26	7.69				Y
27	7.69				Y
28	7.67				Y
29	7.67				Y
30	7.68				Y
31	7.64				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Lafayette

Entry Point: A

Sample Period: Jan. 2026  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH  (Alkalinity)

Alk  (Orthophosphate)

PO4

Other

Print Name: Greg Robinson

Signature: [Signature]

Date: 02-03-2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's