

Day	pH	Alk	Phos	Other	Y/N
1	7.64				Y
2	7.63				Y
3	7.63				Y
4	7.61				Y
5	7.65				Y
6	7.60				Y
7	7.65				Y
8	7.67				Y
9	7.68				Y
10	7.68				Y
11	7.67				Y
12	7.68				Y
13	7.63				Y
14	7.57				Y
15	7.55				Y
16	7.50				Y
17	7.69				Y
18	7.69				Y
19	7.69				Y
20	7.67				Y
21	7.74				Y
22	7.74				Y
23	7.68				Y
24	7.77				Y
25	7.80				Y
26	7.83				Y
27	7.86				Y
28	7.86				Y
29	7.85				Y
30	7.85				Y
31	7.84				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Lafayette

Entry Point: A

Sample Period: 03 - 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	<input type="checkbox"/>
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Greg Robinson

Signature: [Signature]

Date: 04-06-2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's