

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.6				Y
7	7.6				Y
8	8.2				Y
9	8.1				Y
10	8.0				Y
11	8.0				Y
12	7.4				Y
13	7.8				Y
14	7.7				Y
15	7.8				Y
16	7.8				Y
17	7.8				Y
18	7.7				Y
19	7.7				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.7				Y
25	7.6				Y
26	7.5				Y
27	7.6				Y
28	7.6				Y
29	7.7				Y
30	#N/A				
31	#N/A				
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Mar-21
Month/Year

Number of excursions during this month 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	7.0	9.0
Alk		
PO4		
Other		

(Alkalinity)
(Orthpphosphate)
()

Print Name: Chris Germond

Signature: Chris Germond

Date: 3-2-2021

Sent to DWP within 10 days after end of sampling period.