

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.6				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.2				Y
7	7.2				Y
8	7.4				Y
9	7.4				Y
10	7.3				Y
11	7.3				Y
12	7.4				Y
13	7.3				Y
14	7.6				Y
15	7.5				Y
16	7.5				Y
17	7.4				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.8				Y
22	7.5				Y
23	7.5				Y
24	7.5				Y
25	7.4				Y
26	7.5				Y
27	7.6				Y
28	7.3				Y
29	7.4				Y
30	7.2				Y
31	7.4				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: May-21  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameter(s) as set by State:**

	MIN	MAX	
pH	7.0	9.0	
Alk			(Alkalinity)
PO4			(Orthpphosphate)
Other			( )

Print Name: Chris Germond

Signature: Chris Germond

Date: 6/3/21  
Sent to DWP within 10 days after end of sampling period.