

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.4				Y
3	7.4				Y
4	7.7				Y
5	7.5				Y
6	7.5				Y
7	7.6				Y
8	7.5				Y
9	7.5				Y
10	7.6				Y
11	7.7				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.8				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.5				Y
22	7.7				Y
23	7.8				Y
24	7.7				Y
25	7.8				Y
26	7.6				Y
27	7.5				Y
28	8.0				Y
29	7.7				Y
30	7.8				Y
31	#N/A				
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Jun-21  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	7.0	9.0
Alk		
PO4		
Other		

(Alkalinity)  
(Orthpphosphate)  
(\_\_\_\_\_)

Print Name: Chris Germond

Signature: Chris Germond

Date: 7/6/21

Sent to DWP within 10 days after end of sampling period.