

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.5				Y
3	7.5				Y
4	7.4				Y
5	7.4				Y
6	7.5				Y
7	7.4				Y
8	7.4				Y
9	7.4				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.4				Y
14	7.3				Y
15	7.3				Y
16	7.4				Y
17	7.4				Y
18	7.5				Y
19	7.6				Y
20	7.5				Y
21	7.3				Y
22	7.3				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.6				Y
27	7.5				Y
28	7.5				Y
29	7.4				Y
30	7.5				Y
31	#N/A				
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Sep-21
Month/Year

Number of excursions during this month 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

	MIN	MAX	
pH	7.0	9.0	
Alk			(Alkalinity)
PO4			(Orthpphosphate)
Other			()

Print Name: Chris Germond

Signature: Chris Germond

Date: 10/6/21
Sent to DWP within 10 days after end of sampling period.

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Notes:

9/13/2021;	Finish pH read 0 at 10:50 caused by maintenance on pH probe. Lowest pH of the day was 7.43 at 11:51.
------------	--